

## ANALYTICAL REPORT

Mr. Richard Tyler  
MILBANK MANUFACTURING INC  
1400 E. Havens Street  
Kokomo, TN 56901-3188

09/22/2000

Job Number: 00.04756

Page 1 of 3

Enclosed are the Analytical Results for the following samples  
submitted to TestAmerica, Inc. Indianapolis Division for analysis:

Project Description: WASTEWATER ANALYSTS

Sample Number	Sample Description	Date Taken	Time Taken	Date Received
274796	WEEKLY COMPOSITE	09/07/2000	15:30	09/08/2000

TestAmerica, Inc. certifies that the analytical results contained  
herein apply only to the specific samples analyzed.

TestAmerica Incorporated-Indianapolis Division is in compliance with  
the National Environmental Laboratory Accreditation Program (NELAP)  
Standards.

Reproduction of this analytical report is permitted only in its  
entirety.

## ANALYTICAL REPORT

Mr. Richard Tyler  
MILBANK MANUFACTURING INC  
1400 F. Havens Street  
Kokomo, IN 56901-3188

09/22/2000

Job No.: 00.04756  
Page 2 of 3

Date Received: 09/08/2000  
Job Description: WASTEWATER ANALYSIS

Sample Number / Sample I.D.	Sample Date/	Analyst	Reporting
Parameters	Units	Date & Time Analyzed	Limit
274796	WEEKLY COMPOSITE	09/07/2000 15:30	
Zinc, ICP	<0.020	mg/L	09/21/2000 19:49 EPA 200.7 <0.020

Page 3 of 3

**KEY TO ABBREVIATIONS**

- < Less than; when appearing in the result column, indicates analyte not detected at or above the Reporting Limit.
- % Percent: To convert ppm to %, divide result by 10,000. To convert % to ppm, multiply the result by 10,000.
- \* Indicates the Reporting Limit is elevated due to insufficient sample volume.
- mg/l Part per million; Concentration in units of milligrams of analyte per liter of aqueous sample.
- ug/L Part per billion; Concentration in units of micrograms of analyte per Liter of aqueous sample.
- mg/kg Part per million; Concentration in units of milligrams of analyte per kilogram of non-aqueous sample.
- ug/kg Part per billion; Concentration in units of micrograms of analyte per kilogram of non-aqueous sample.
- a Indicates the sample concentration was quantitated using a diesel fuel standard.
- b Indicates the analyte of interest was also found in the method blank.
- c Sample resembles unknown Hydrocarbon.
- dw When indicated, the result is reported on a dry weight basis. The contribution of the moisture content in the sample has been subtracted when calculating the concentration.
- d1 Indicates the analyte has elevated Reporting Limit due to high concentration.
- d2 Indicates the analyte has elevated Reporting Limit due to matrix.
- e Indicates the reported concentration is estimated.
- g Indicates the sample concentration was quantitated using a gasoline standard.
- h Indicates the sample was analyzed past recommended holding time.
- i Insufficient spike concentration due to high analyte concentration in the sample.
- j Indicates the reported concentration is below the Reporting Limit.
- k Indicates the sample concentration was quantitated using a kerosene standard.
- l Indicates an MS/MSD was not analyzed due to insufficient sample. An LCS / LCS Duplicate provided for precision.
- m Indicates the sample concentration was quantitated using a mineral spirits standard.
- o Indicates the sample concentration was quantitated using a motor oil standard.
- p Indicates the sample was post spiked due to sample matrix.
- q Indicates MS/MSD exceeded control limits. The associated sample may exhibit similar matrix bias. All other quality control indicators are in control.
- r Indicates the sample was received past recommended holding time.
- u Indicates the sample was received improperly preserved and/or improperly contained.
- uj Indicates the result is below the Reporting Limit and is considered estimated.

MIL0003799

DATE: SEPTEMBER 7<sup>TH</sup>, 2000

**MILBANK MANUFACTURING COMPANY**

TIME	METER READING	INITIALS
7:30	44920	SLH
8:00	45070	SLH
8:30	45260	SLH
9:00	45500	SLH
9:30	45720	SLH
10:00	45930	SLH
10:30	46140	SLH
11:00	46380	SLH
11:30	46590	SLH
12:00	46730	SLH
12:30	46950	SLH
1:00	47160	SLH
1:30	47330	SLH
2:00	47540	SLH
2:30	47760	SLH
3:00	47890	SLH
3:30	47980	SLH

Please test for the following highlighted

9-7-00  
Page 3 of 19

# PART I

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: (1)

### Discharge Limitations

### Monitoring Requirements

<u>Regulated Parameter</u>	<u>Maximum for Any one Day mg/L</u>	<u>Monitoring Frequency</u>	<u>Sample Type</u>
Cadmium[5]	.02	Semi-Annual	Composite[2]
Total Chromium[5]	2.0	Semi-Annual	Composite[2]
Copper[5]	0.60	Semi-Annual	Composite[2]
Cyanide	0.50	Semi-Annual	Grab
Lead[5]	0.10	Semi-Annual	Composite[2]
Nickel[5]	0.80	Semi-Annual	Composite[2]
Silver[5]	0.24	Semi-Annual	Composite[2]
Zinc[5]	1.25	1 X Week	Composite[2]
Oil and Grease[6]	100	Semi-Annual	Grab
TPH[6]	(Monitor and report)	Semi-Annual	Grab
pH	6-10	Daily	Grab
CBOD [4]	(Monitor and report)	1 X Month	Composite[2]
Ammonia [4]	(Monitor and report)	1 X Month	Composite[2]
COD [4]	(Monitor and report)	1 X Month	Composite[2]
TSS [4]	(Monitor and report)	1 X Month	Composite[2]
Flow	N/A	Daily [3]	
TTO	2.13	Semi-Annual	Grab
Phenol	0.50	Semi-Annual	Grab
Molybdenum[5]	(Monitor and report)	1 X Month	Composite[2]



DAILY: EVERY DAY SYSTEM RUNS

1X WEEK: 1 DAY OF WEEK COMPOSITE IS TAKEN (USUALLY THURSDAY)

1X MONTH: TO BE TAKEN FIRST WEEK COMPOSITE IS TAKEN FOR THAT MONTH

SEMI-ANNUAL: TO BE TAKEN FIRST WEEK IN JUNE AND FIRST WEEK IN DECEMBER

## PART I

### A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: (1)

#### Discharge Limitations

#### Monitoring Requirements

	Regulated Parameter	Maximum for Any one Day mg/L	RESULT	DATE TAKEN	Monitoring Frequency	Sample Type
Cd	Cadmium[5]	.02			Semi-Annual	Composite[2]
Cr	Total Chromium[5]	2.0			Semi-Annual	Composite[2]
Cu	Copper[5]	0.60			Semi-Annual	Composite[2]
Ca	Cyanide	0.50			Semi-Annual	Grab
Pb	Lead[5]	0.10			Semi-Annual	Composite[2]
Ni	Nickel[5]	0.80			Semi-Annual	Composite[2]
Ag	Silver[5]	0.24			Semi-Annual	Composite[2]
Zn	Zinc[5]	1.25	<0.020	9-7-00	1 X Week	Composite[2]
FOG	Oil and Grease[6]	100			Semi-Annual	Grab
Oil + GREASE (HYDROCARBONS)	TPH[6]	(Monitor and report)			Semi-Annual	Grab
	pH	6-10			Daily	Grab
	CBOD [4]	(Monitor and report)			1 X Month	Composite[2]
Nh3	Ammonia [4]	(Monitor and report)			1 X Month	Composite[2]
	COD [4]	(Monitor and report)			1 X Month	Composite[2]
	TSS [4]	(Monitor and report)			1 X Month	Composite[2]
	Flow	N/A			Daily [3]	
*	FTO	2.13			Semi-Annual	Grab
	Phenol	0.50			Semi-Annual	Grab
Mo	Molybdenum[5]	(Monitor and report)			1 X Month	Composite[2]

SEND TTO CERTIFICATION STATEMENT IN LIEU OF MONITORING ALONG WITH 40 CFR CATEGORICAL STATEMENT. MUST BE SENT EVERY JUNE AND DECEMBER (SEMI-ANNUAL)

MIL0003802